

**Exhibit A – RFQ #403416 and Addendum #1**

**REQUEST FOR QUOTATION # 403416 (REVISED)  
SUBSTATION BATTERY AND RACK SYSTEM INSTALLATION**



**ALL QUOTATIONS SHALL BE SUBMITTED ONLINE VIA THE PLANETBIDS PORTAL OR VIA A SEALED ENVELOPE ADDRESSED TO:**

**CITY OF GLENDALE  
PURCHASING OFFICE  
141 N. GLENDALE AVE, ROOM 346  
GLENDALE, CA 91206**

**PAPER SUBMITTALS SHALL BE CLEARLY IDENTIFIED IN THE LOWER LEFT-HAND CORNER OF THE ENVELOPE WITH THE RFQ NUMBER AND NAME.**

**ALL SUBMITTALS, INCLUDING THOSE SUBMITTED ELECTRONICALLY, SHALL BE ACCEPTED UNTIL 11:00 AM PST, TUESDAY, OCTOBER 19, 2021**

**IT IS THE VENDOR'S SOLE RESPONSIBILITY TO HAVE THEIR RESPONSE DELIVERED TO THE DESIGNATED ADDRESS, BEFORE THE APPOINTED TIME. THE CITY OF GLENDALE, ADMINISTRATIVE SERVICES' TIME CLOCK SHALL BE THE OFFICIAL TIME.**

**LATE SUBMITTALS WILL NOT BE ACCEPTED AND WILL NOT BE OPENED.**

**FAX AND EMAIL SUBMITTALS WILL NOT BE ACCEPTED.**

**IT IS THE VENDOR'S SOLE RESPONSIBILITY TO HAVE THEIR RESPONSE DELIVERED TO THE DESIGNATED ADDRESS OR PLANET BIDS PORTAL, BEFORE THE APPOINTED TIME.**

## REQUEST FOR QUOTATION # 403416 (REVISED) SUBSTATION BATTERY AND RACK SYSTEM INSTALLATION

### SECTION A

#### A1. INTRODUCTION

THE CITY OF GLENDALE ("CITY") IS SOLICITING QUOTATIONS TO REMOVE EXISTING BATTERY SYSTEM AND FURNISH AND INSTALL A NEW BATTERY SYSTEM AT THE SCHOLL CANYON SUBSTATION.

#### A2. MANDATORY JOB WALK AND INQUIRIES

DATE: THURSDAY, OCTOBER 7, 2021

TIME: 8:30 AM

LOCATION: SCHOLL SUBSTATION, 201 RICHLAND AVE, GLENDALE, CA 91206

MEETING PLACE: THE SUBSTATION FRONT GATE

POC: MIGUEL IBANEZ, OFFICE 818-550-4565, CELL 818- 913-4834; [MIBANEZ@GLENDALECA.GOV](mailto:MIBANEZ@GLENDALECA.GOV)  
CLINT MORENO, CELL 818-254-5534, [CMORENO@GLENDALECA.GOV](mailto:CMORENO@GLENDALECA.GOV)

#### IMPORTANT:

PURSUANT TO SECTION 15 (B) OF THE SAFER AT HOME ORDER OF THE COUNTY OF LOS ANGELES DEPARTMENT OF PUBLIC HEALTH, PUBLIC WORKS CONSTRUCTION IS AN ESSENTIAL INFRASTRUCTURE AND THEREFORE PROVIDING ANY SERVICE FOR THIS PROJECT DURING THE EFFECTIVE DATE OF THIS ORDER IS COMPLIANT WITH THE ORDER. TO THE EXTENT PRACTICABLE, SOCIAL DISTANCING MUST BE FOLLOWED DURING THE JOB WALK.

CONTRACTORS MUST BRING THEIR OWN PPE, SPECIFICALLY FACE MASKS, TO THE JOB WALK.

- A 2.1. PLAN TO BE ON TIME, LATE CONTRACTORS WILL NOT BE ALLOWED TO SIGN-IN AFTER THE JOB WALK STARTS
- A 2.2. ONLY CONTRACTORS LISTED ON THE JOB WALK SIGN-IN SHEET WILL BE ALLOWED TO SUBMIT A BID.
- A 2.3. ALL CONTRACTORS SHALL BE REQUIRED TO MAKE THEIR OWN SITE INSPECTION. CONTRACTORS SHOULD TAKE THEIR OWN MEASUREMENTS AND VERIFY ALL FIELD CONDITIONS.
- A 2.4. TO RSVP FOR THE JOB WALK, PLEASE CONTACT:  
MIGUEL IBANEZ, OFFICE 818-550-4565, CELL 818- 913-4834; [MIBANEZ@GLENDALECA.GOV](mailto:MIBANEZ@GLENDALECA.GOV)  
CLINT MORENO, CELL 818-254-5534, [CMORENO@GLENDALECA.GOV](mailto:CMORENO@GLENDALECA.GOV)

#### A3. METHOD OF AWARD & PAYMENT

- A 3.1. ONCE AN AWARD HAS BEEN MADE A CITY OF GLENDALE PURCHASE ORDER OR SERVICE AUTHORIZATION WILL BE ISSUED TO THE SELECTED CONTRACTOR. SERVICE AUTHORIZATIONS AND/OR PURCHASE ORDERS ISSUED AS A RESULT OF THIS RFQ SHALL BE SUBJECT TO THE CITY OF GLENDALE'S TERMS & CONDITIONS, WHICH CAN BE FOUND AT: [WWW.GLENDALEPURCHASING.ORG](http://WWW.GLENDALEPURCHASING.ORG)
- A 3.2. ALL PAYMENTS SHALL BE MADE AFTER SUCCESSFUL COMPLETION OF THE PROJECT. NO ADVANCE PAYMENT IS ALLOWED FOR THIS PROJECT.
- A 3.3. THE CITY OF GLENDALE SHALL NOT BE HELD LIABLE FOR ANY COSTS INCURRED IN THE PREPARATION AND PRODUCTION OF A QUOTATION IN RESPONSE TO THIS RFQ, OR FOR ANY WORK PERFORMED PRIOR TO THE ISSUANCE OF A PURCHASE ORDER.
- A 3.4. AWARD MADE FOR THIS REQUEST INCLUDING ALL CHANGE ORDERS SHALL NOT EXCEED \$50,000.

**A4. REJECTION OF QUOTATIONS**

THIS REQUEST FOR QUOTATION DOES NOT COMMIT THE CITY OF GLENDALE TO AWARD A CONTRACT, OR TO PROCURE OR TO CONTRACT FOR SERVICES OR SUPPLIES. THE CITY OF GLENDALE RESERVES THE RIGHT TO ACCEPT OR REJECT ANY OR ALL QUOTATIONS RECEIVED AS A RESULT OF THIS REQUEST; OR TO CANCEL IN PART OR IN ITS ENTIRETY THIS RFQ.

**A5. BOND**

PAYMENT AND PERFORMANCE BONDS ARE REQUIRED IF BID IS MORE THAN \$25,000.

THIS CONTRACT/PURCHASE ORDER SHALL NOT BE VALID UNLESS VENDOR/ CONTRACTOR FURNISH PAYMENT AND A PERFORMANCE BONDS IN AN AMOUNT EQUAL TO ONE HUNDRED PERCENT (100%) OF THE CONTRACT/PURCHASE ORDER VALUE. BOND MUST BE APPROVED BY THE CITY OF GLENDALE PURCHASING ADMINISTRATOR TO BE CONSIDERED ACCEPTABLE.

**A6. INSURANCE & INDEMNIFICATION**

THE SUCCESSFUL CONTRACTOR SHALL PROVIDE INSURANCE REQUIREMENTS WITHIN 30 DAYS OF WRITTEN NOTIFICATION.

- A 6.1 SHOULD INSURANCE BE IN NON-COMPLIANCE, AS DETERMINED BY THE CITY ATTORNEY, WITHIN TIME SPECIFIED, YOUR PROPOSAL MAY BE REJECTED IN ITS ENTIRETY AND THE NEXT BIDDER GIVEN THE OPPORTUNITY TO COMPLY.
- A 6.2 ORIGINAL COPIES OF THE WORKER'S COMPENSATION, GENERAL LIABILITY, AND PROPERTY DAMAGE INSURANCE DOCUMENTS MUST BE FURNISHED TO THE CITY OF GLENDALE, RISK MANAGEMENT OFFICE, 613 E. BROADWAY, SUITE 220, GLENDALE, CA 91206, BEFORE ANY WORK IS STARTED.
- A 6.3 LIABILITY INSURANCE MUST HAVE AN ENDORSEMENT OR BINDER EXECUTED BY THE INSURANCE COMPANY ITSELF, READING: "THE CITY OF GLENDALE, CALIFORNIA, ITS AGENTS, OFFICERS, AND EMPLOYEES ARE NAMED AS ADDITIONAL INSURED UNDER THE POLICY.
- A 6.4 THIS INSURANCE IS PRIMARY TO THE COVERAGE OF THE CITY OF GLENDALE". POLICY TO READ: "WILL GIVE A THIRTY (30) DAY NOTICE OF CANCELLATION, TERMINATION OR MATERIAL CHANGE OF THE POLICY TO THE CITY OF GLENDALE. "WILL ENDEAVOR" IS NOT ACCEPTABLE.
- A 6.5 BOTH DOCUMENTS MUST BE SIGNED BY AN AUTHORIZED REPRESENTATIVE OF THE INSURANCE COMPANY. THE INSURANCE MUST BE VALID DURING THE LIFE OF THE AGREEMENT.
- A 6.6 COMPLETE INSURANCE REQUIREMENTS ARE POSTED ON: [WWW.GLENDALEPURCHASING.ORG](http://WWW.GLENDALEPURCHASING.ORG).

**A7. SUBMITTALS**

- A 7.1 ALL QUOTATIONS SHALL BE SUBMITTED **EITHER** IN AN ELECTRONIC FILE VIA THE PLANET BIDS PORTAL **OR** A SEALED ENVELOPE ADDRESSED TO:  
  
CITY OF GLENDALE  
PURCHASING DEPARTMENT  
141 N. GLENDALE AVENUE, ROOM #346  
GLENDALE CA 91206-4499
- A 7.2 SUBMITTALS SHALL BE CLEARLY IDENTIFIED IN THE LOWER LEFT-HAND CORNER OF THE ENVELOPE WITH RFQ NUMBER AND PROJECT NAME.
- A 7.3 SUBMITTALS SHALL BE ACCEPTED UNTIL **TUESDAY, OCTOBER 19, 2021 AT 11:00 AM**
- A 7.4 IT IS THE VENDOR'S SOLE RESPONSIBILITY TO HAVE THEIR RESPONSE DELIVERED TO THE DESIGNATED ADDRESS, BEFORE THE APPOINTED TIME. THE CITY OF GLENDALE, ADMINISTRATIVE SERVICES' TIME CLOCK SHALL BE THE OFFICIAL TIME. LATE SUBMITTALS SHALL NOT BE ACCEPTED AND SHALL NOT BE OPENED.

## REQUEST FOR QUOTATION # 403416 (REVISED)

### SUBSTATION BATTERY AND RACK SYSTEM INSTALLATION

#### SECTION B

##### B1. SCOPE OF WORK

THIS UTILITY GRADE 125-VOLT STATIONARY BATTERY SYSTEM IS FOR THE OPERATION OF HIGH VOLTAGE CIRCUIT BREAKERS, MICROPROCESSOR BASED RELAYS AND COMMUNICATION DEVICES. IT IS TO BE INSTALLED AT THE SCHOLL SUBSTATION IN THE CITY OF GLENDALE. THE CONTRACTOR SHALL FURNISH AND INSTALL ONE (1) NEW BATTERY SYSTEM TO REPLACE THE EXISTING BATTERY SYSTEM IN ACCORDANCE WITH THESE SPECIFICATIONS.

- B 1.1 THE BATTERY ASSEMBLY SHALL BE INSTALLED UTILIZING THE AVAILABLE SPACE IN THE SUBSTATION IN A MANNER THAT PROMOTES EASE OF ACCESS FOR MAINTENANCE.
- B 1.2 THE CONTRACTOR SHALL SUBMIT INSTALLATION DRAWINGS SHOWING THE RACK DESIGN, BATTERY PLACEMENT AND ELECTRICAL CONNECTIONS FOR THE SUBSTATION AND A LIST OF COMPONENTS AND MATERIALS SUPPLIED FOR GWP'S APPROVAL. NO INSTALLATION WORK WILL COMMENCE UNTIL DRAWINGS AND MATERIALS ARE APPROVED.
- B 1.3 THE CONTRACTOR SHALL BE RESPONSIBLE FOR ALL THE WORK ASSOCIATED WITH THIS PROJECT, WHICH INCLUDES BUT NOT LIMITED TO INSTALLATION OF TEMPORARY BATTERY BANK TO PREVENT DC POWER LOSS, EQUIPMENT AND INSTALLATION MATERIALS, REMOVING AND PROPERLY DISPOSING OF THE EXISTING BATTERY SYSTEM. THE CONTRACTOR SHALL BE LICENSED BY THE STATE OF CALIFORNIA FOR WORKING WITH AND TRANSPORTING THESE TYPES OF HAZARDOUS MATERIALS. IN ADDITION, THE CONTRACTOR SHALL ISSUE TO THE CITY OF GLENDALE A CERTIFICATE, LEGALLY AND PROPERLY DOCUMENTED, SHOWING DISPOSAL WAS DONE IN CONFORMANCE WITH ALL LAWS, RULES AND REGULATIONS WHETHER FEDERAL, STATE, COUNTY OR OTHERS BEFORE COMPLETE PAYMENT IS MADE.
- B 1.4 BATTERY TYPE  
THE BATTERY SHALL BE UTILITY GRADE, STATION AND LEAD CALCIUM TYPE WITH THE FOLLOWING CHARACTERISTICS:
- B 1.4.1 COMPLETELY SEALED,
  - B 1.4.2 NO GEL ALLOWED,
  - B 1.4.3 INDIVIDUAL TERMINALS PER CELL TO ALLOW INDIVIDUAL CELL MONITORING,
  - B 1.4.4 FLAME RETARDANT COVER SEALS SHALL BE LEAK PROOF AND POST SEALS SHALL BE ACID TIGHT.
  - B 1.4.5 EACH CELL SHALL BE MARKED FOR LOW AND HIGH ELECTROLYTE LEVELS,
  - B 1.4.6 JAR SHALL BE MADE FROM CLEAR GLASS OR CLEAR PLASTIC,
  - B 1.4.7 SPECIFIC GRAVITY OF 1.215,
  - B 1.4.8 20-YEAR LIFE EXPECTANCY,
  - B 1.4.9 FLAME ARRESTORS FOR INCREASED OPERATIONAL SAFETY,
  - B 1.4.10 CAPABLE OF CONTINUOUS CHARGE BY A STANDARD DC VOLTAGE – REGULATED RECTIFIER,
  - B 1.4.11 OPERATING TEMPERATURE RANGE SHALL BE FROM 32°F (0°C) TO 120°F (49°C),
  - B 1.4.12 STACKABLE IN A HORIZONTAL OR VERTICAL CONFIGURATION.
- B 1.5 NATIONAL STANDARD  
THE EQUIPMENT FURNISHED UNDER THESE SPECIFICATIONS SHALL BE DESIGNED, CONSTRUCTED, AND TESTED TO MEET ALL OF THE APPLICABLE REQUIREMENTS OF THE IEEE, ANSI, ASTM AND NEMA STANDARDS, AS LAST REVISED. THE UNDERWRITER'S LABORATORIES RECOGNITION COMPONENT SERVICE SHALL CURRENTLY LIST THE BATTERY SYSTEM.
- B 1.6 RATING  
THE CAPACITY OF THE BATTERY BANK SHALL BE IN THE RANGE OF 256 TO 350 AMPERE-HOURS DEPENDING ON STATION NEEDS. THE BATTERY SHALL BE DELIVERED AT 100% OF RATING. THE AMPERE-HOUR CAPACITY SHALL BE BASED ON THE 8-HOUR DISCHARGED RATE, STARTING WITH A FULLY-CHARGED ELECTROLYTE HAVING 2.25-2.28 VOLTS PER CELL AND A FINAL CELL VOLTAGE OF 1.75 VOLTS WITH A BATTERY ELECTROLYTE TEMPERATURE NOT EXCEEDING 77°F. THE BATTERY SYSTEM SHALL CONTAIN 60 CELLS IN SERIES. THE BATTERY SHALL BE CAPABLE OF NOMINAL VOLTAGE RECOVERY AFTER BEING SUBJECTED TO 1500 DEEP – CYCLE DISCHARGES OR CAPABLE OF STANDBY USE FOR 20 YEARS. BATTERIES SHALL HAVE A LOW SELF-DISCHARGE RATE OF LESS THAN ONE PERCENT PER WEEK.

**B 1.7**     ACCESSORIES

THE FOLLOWING ACCESSORIES SHALL BE FURNISHED WITH THE BATTERY SYSTEM:

- B 1.7.1    MODULAR STEEL RACKS AND ASSEMBLY PARTS FOR A VERTICAL OR HORIZONTAL CONFIGURATION. ALL HARDWARE FOR MODULAR STACKING SHALL BE STAINLESS STEEL,
- B 1.7.2    CELL IDENTIFICATION NUMERALS AND POLARITY INDICATORS,
- B 1.7.3    ALL REQUIRED INTER-CELL AND INTER-ROW CONNECTORS, FOR EACH BATTERY,
- B 1.7.4    ONE-CONNECTOR BOLT WRENCH, TORQUE WRENCH, TERMINAL SILICON GREASE, AND TORQUE-TIGHTENING INFORMATION,
- B 1.7.5    A SUFFICIENT NUMBER OF STAINLESS STEEL BOLTS, WASHERS, NUTS, AND HARDWARE, PLUS NECESSARY INSTRUCTIONS TO COMPLETE THE ASSEMBLY OF THE ENTIRE BATTERY SYSTEM AS A FLOOR-MOUNTED UNIT,
- B 1.7.6    THREE SET OF INSTRUCTION BOOK DESCRIBING THE RACK INSTALLATION, CELL CONNECTION, MEASURING TECHNIQUE, AND MAINTENANCE PROCEDURES AND CYCLES OF THE BATTERY SYSTEM.

**B 1.8**     BATTERY RACK MODULE

THE BATTERY RACK-STEEL MODULE STACKING SYSTEM SHALL ACCOMMODATE THE BATTERY CELLS FURNISHED UNDER THESE SPECIFICATIONS. THE STEEL RACK MODULE SHALL BE OF HIGH SEISMIC RATING CONSISTING OF FRAMING, CHANNELS, AND NECESSARY BRACING. THESE SHALL BE PRIMED AND THEN PAINTED WITH A MINIMUM OF TWO COATS OF ACID-RESISTANT SYNTHETIC ENAMEL OR EQUIVALENT POWDER COATING.

**B 1.9**     SPILL CONTAINMENT

SPILL CONTAINMENT SYSTEM SHALL BE INCLUDED TO ABSORB AND NEUTRALIZE ELECTROLYTE LEAKS FROM THE BATTERIES. FLAME RETARDANT PLASTIC LINER SHALL FIT UNDER THE BATTERY RACK WITHOUT ANY NEED FOR FLOOR PREPARATION. SPILL CONTAINMENT BARRIERS AND ABSORBENT PILLOWS SHALL BE OF NON-CORROSIVE MATERIAL AND EASILY MODIFIED TO THE PROPER SIZE.

**B 1.10**    TESTS

THE CONTRACTOR SHALL PROVIDE TEST REPORTS AND CERTIFY IN WRITING THAT ALL CELLS IN THE BATTERY WERE TESTED AT THE FACTORY AND HAVE CAPACITY STRENGTH OF 100% AND FULLY CHARGED AND READY FOR SERVICE BEFORE SHIPMENT;

**B 1.11**    GUARANTEES

THE CONTRACTOR SHALL GUARANTEE A BATTERY DESIGN LIFE OF TWENTY YEARS AND SHALL GUARANTEE THAT ALL EQUIPMENT, MATERIALS AND WORKMANSHIP FURNISHED UNDER THESE SPECIFICATIONS SHALL BE FREE FROM DEFECTS, WHEN OPERATED ACCORDING TO THE MANUFACTURER'S INSTRUCTIONS. THE BIDDER SHALL PROVIDE ALL WARRANTY DETAILS, INCLUDING WARRANTY PRORATION EQUATIONS IF APPLICABLE, ALONG WITH THE BID. FURTHERMORE, THE CONTRACTOR SHALL FULLY CERTIFY ALL CELLS TO BE CAPABLE OF 100% CAPACITY FOR A PERIOD OF TWO YEARS BEGINNING WITH THE INITIAL START-UP.

**B 1.12**    EXISTING BATTERY SYSTEM

- B 1.12.1   THE EXISTING BATTERY SYSTEM CONTAINS 60 CELLS IN SERIES.
- B 1.12.2   THE EXISTING BATTERY TYPE IS AS FOLLOWING: 60-CELL GNB VRLA 90G07  
256AMP-HRS AT 8 HR. RATE; 1.75VPC.; NOM. 2 VOLTS

**B 1.13**    REMOVAL AND PROPER DISPOSAL OF EXISTING BATTERY SYSTEM

THE REMOVAL AND PROPER DISPOSAL OF THE EXISTING BATTERY SYSTEM SHALL BE CARRIED OUT BY THE CONTRACTOR AS FOLLOWS:

- B 1.13.1   DISMANTLE BATTERY SYSTEM WHERE LOCATED.
- B 1.13.2   HAUL OR REMOVE THE BATTERY SYSTEM FROM PRESENT LOCATION TO OUTSIDE THE BUILDING.

**B2.     PREVAILING WAGES & WORK REQUIREMENTS**

- B 2.1     WAGE RATES: THE CONTRACTOR SHALL PAY PREVAILING WAGE IN COMPLIANCE WITH CALIFORNIA LABOR CODE SECTIONS 1771, 1774 - 1776, 1777.5, 1813 AND 1815 OR ANY SUCCESSOR LEGISLATION.
- B 2.2     ALL WORK SHALL BE PERFORMED BY THE CONTRACTOR'S WORKFORCE. NO SUBCONTRACTING IS ALLOWED.
- B 2.3     SB 854 COMPLIANCE: IN ACCORDANCE WITH CALIFORNIA SENATE BILL 854 (STAT. 2014, CHAPTER 28), ALL PROSPECTIVE BIDDERS SHALL BE REGISTERED WITH STATE OF CALIFORNIA DEPARTMENT OF INDUSTRIAL RELATION (DIR) AND PAY AN ANNUAL FEE TO THE DIR.

- B 2.4 THE AWARDED CONTRACTOR SHALL HAVE A VALID CALIFORNIA CONTRACTOR'S LICENSE WITH THE CLASSIFICATION REQUIRED TO PERFORM SPECIFIED SERVICES AND SCOPE OF WORK.
- B 2.5 SAFETY SHALL BE OF THE UTMOST IMPORTANCE, THE CONTRACTOR TO TAKE ALL NECESSARY STEPS TO PROTECT THEIR EMPLOYEES, THE PUBLIC, PRIVATE PROPERTY, VEHICLES, CITY EMPLOYEES, AND PROPERTY DAMAGE, INCLUDING PLANTS, TREES, SHRUBS, ETC. DURING THE PERFORMANCE OF THIS PROJECT.
- B 2.6 ALL WORK SHALL BE PERFORMED BETWEEN THE HOURS OF **8:00 A.M. AND 4:30 P.M.** (UNLESS SPECIFICALLY AUTHORIZED BY THE PROJECT MANAGER), ARRANGEMENTS FOR ADMISSION TO THE CITY'S BUILDINGS SHALL BE COORDINATED WITH THE PROJECT MANAGER. NO UNNECESSARY INTERFERENCE WITH PUBLIC OR EMPLOYEE USE OF THE FACILITY.
- B 2.7 ALL WORK SHALL BE DONE IN THE MOST WORKMANLIKE MANNER, AS ACCEPTABLE WITHIN THE TRADE.
- B 2.8 UPON COMPLETION OF THE WORK BY THE CONTRACTOR, FINAL INSPECTION SHALL BE MADE BY PROJECT MANAGER, AND UPON APPROVAL THE PROJECT WILL BE ACCEPTED BY THE CITY AND PAYMENT AUTHORIZED.

QUOTATION

THE RESPONDENT, IN COMPLIANCE WITH THE ABOVE REFERENCE PROJECT, HAVING EXAMINED THE SPECIFICATIONS, CITY OF GLENDALE INSURANCE REQUIREMENTS, CITY OF GLENDALE PURCHASE ORDER/SERVICE AUTHORIZATION TERMS AND CONDITIONS, RELATED DOCUMENTS AND THE SITE OF THE PROPOSED WORK, AND HAVING BECOME COMPLETELY FAMILIAR WITH LOCAL CONDITIONS SURROUNDING THE PROPOSED WORK, INCLUDING AVAILABILITY OF MATERIALS AND LABOR, HEREBY, PROPOSES TO PERFORM ALL WORK AT RATES STATED BELOW, WHICH ARE TO COVER ALL EXPENSES INCURRED IN PERFORMING THE WORK.

**SCOPE:**           **RFQ # 403416**  
                          **SUBSTATION BATTERY AND RACK SYSTEM INSTALLATION**

**TOTAL COST: \$ \_\_\_\_\_ INCLUDING ALL LABOR, MATERIAL, FREIGHT, PERFORMANCE AND PAYMENT BOND (IF TOTAL IS MORE THAN \$25,000) AND APPLICABLE TAX**

**COMPLETION TIME: \_\_\_\_\_ DAYS AFTER NOTICE TO PROCEED**

SB 854 COMPLIANCE INFORMATION (Per section B 2.3 of spec):

CONTRACTOR'S LEGAL NAME: \_\_\_\_\_

REGISTRATION NO WITH DIR: \_\_\_\_\_

CONTRACTOR'S LICENSE #: \_\_\_\_\_

CONTACT PERSON: \_\_\_\_\_

E-MAIL: \_\_\_\_\_

PHONE: \_\_\_\_\_

FAX: \_\_\_\_\_

SIGNATURE: \_\_\_\_\_

DATE: \_\_\_\_\_



CITY OF GLENDALE, CALIFORNIA  
Administrative Services Division  
PURCHASING

141 North Glendale Avenue, Room 346  
Glendale, California 91206-4499  
(818) 548-2102 FAX (818) 956-3286  
www.ci.glendale.ca.us

September 30, 2021

TO: All Potential Bidders

**ADDENDUM #01**  
**REQUEST FOR QUOTATION #403416**  
**SUBSTATION BATTERY AND RACK SYSTEM INSTALLATION**

The following requirements have been changed for Request for Quote #403416 as follows:

1. Section B 1.4 - BATTERY TYPE: THE BATTERY SHALL BE UTILITY GRADE, STATION AND LEAD-ACID TYPE should be replaced with:  
THE BATTERY SHALL BE UTILITY GRADE, STATION AND LEAD-CALCIUM TYPE

All other requirements, terms and conditions of the RFQ remain unchanged.

A signed copy of this Addendum shall be submitted with your quote.

Vendor Name: \_\_\_\_\_ Signature: \_\_\_\_\_

By:

**Christina Gomez**  
**Buyer II**